



Eye/Face Wash, ISTEK Tip EW-ESL, Countertop for Laboratory

Product Code: 15012020-15012525



P/No :15012020 (Stainless Steel) P/No :15012525 (Galvanized and Painted)

Our emergency eye/face washes, which are also available with ATEX certificate (EXPROOF) in order to be used safely in hazardous environments, are produced within the framework of the requirements stipulated by ANSI/ISEA Z358.1-2014 and EN 15154-2 standards in order to provide a safe working environment, and have up-to-date certificates according to the relevant standards.

According to the standards, emergency eye/face washes have to provide a minimum of 11.4 l of uninterrupted potable water per minute for 15 minutes, and the required water flow is met by connecting to mains supply.

The water temperature should be kept constant between 16-38 °C according to the requirements of the standard. If potable water supplied from mains water supply is not sufficient to meet this temperature range, thermostatic mixing valves can be included in the system, which ensures that the ideal temperature is obtained by mixing the water coming from the

hot and cold water sources feeding the mains supply.

Please contact our sales team to get information about our solutions to meet the requirements of ANSI for providing tepid water.

You can review our article to learn more about the exproof products.

Teknik Bilgiler

Our emergency eye/face washes, which are also available with ATEX certificate (EXPROOF) in order to be used safely in hazardous environments, are produced within the framework of the requirements stipulated by ANSI/ISEA Z358.1-2014 and EN 15154-2 standards in order to provide a safe working environment, and have up-to-date certificates according to the relevant standards.

According to the standards, emergency eye/face washes have to provide a minimum of 11.4 l of uninterrupted potable water per minute for 15 minutes, and the required water flow is met by connecting to mains supply.

The water temperature should be kept constant between 16-38 °C according to the requirements of the standard. If potable water supplied from mains water supply is not

sufficient to meet this temperature range, thermostatic mixing valves can be included in the system, which ensures that the ideal temperature is obtained by mixing the water coming from the hot and cold water sources feeding the mains supply.

Please contact our sales team to get information about our solutions to meet the requirements of ANSI for providing tepid water.

You can review our article to learn more about the exproof products.

Laboratory Type Countertop Mounted Eye/Face wash unit.

Eye wash units are designed and intended to be installed in close range of persons working in a potentially hazardous area. The main purpose of these devices is to immediately deliver flushing fluid in sufficient volume to flush the eyes following exposure to injurious substances or heat. With this accomplished the injured person can proceed to medical care.

Rinses eyes and face with clean water via twin spray nozzles.

Push handle operated.



SINCE
1979

