

Technical drawing of the assembly of the upper part of the device. The top view shows a circular base with a central hole of diameter Ø10 and four outer holes of diameter Ø30. The side view shows the assembly of the upper part, including a spring (1), a chain (2), a hook (3), a bolt (4), a nut (5), a washer (6), and a plate (7). The bolt is labeled M10x45.

Static test pressure : 7 bar
Min using pressure : 1,4 bar
Max using pressure : 2,8 bar

NO.	DESCRIPTION	NOTES
7	Water Inlet 1/2"	
6	Push Handle Control for Eyewash	
5	Spray Nozzles	
4	Dust Cover on Eyewash Spray	
3	Eyewash Bowl	
2	1/2" Ball Valve	
1	Water Outlet 1 1/4" (Female)	

										CUSTOMER					
A		FIRST ISSUE		SS		FA		ST							
REV.		DATE		DESCRIPTION		DESIGNED		CHECKED		APPROVED					
STATUS	FOR INFORMATION		☐ FOR RFD/DESIGN		ORIGINAL		EDITION		SIZE		SCALE				
	DESIGNED				SS		A4		1/100						
	CHECKED				FA										
FOR REVIEW				APPROVED		ST									
FOR APPROVAL										PRODUCT					
										15014000					
IST İsci Sağlığı Teçhizatı Sanayi ve Ticaret Ltd Sti Ostim Melih Gökçek Bv 31 Cadde 2269 sokak 42 Ankara Türkiye 06374 www.ist.com.tr Ph 0090312 384 13 00 Fax 0090312 341 73 03										DRAWING NUMBER/DATE:		SHEET: 1		DRAWING NAME:	
										412/16-2		OF: 1		EYEWASH SHOWER	